

Date: \_\_\_\_\_

Page \_\_\_ of \_\_\_

# Inspection Record for Portable Fire Extinguishers

---

Extinguisher Number / Identifier										
Present at designated Location										
No obstruction to access or visibility										
Pressure gauge reading or indicator in the operable range or position										
Fullness determined by weighing or hefting (invert to loosen contents)										
Operating instructions are legible and face outward										
Broken or missing safety seals and tamper indicators										
Physical damage, corrosion, leakage, or clogged nozzle										

**Person performing inspection** Name: \_\_\_\_\_ Signature: \_\_\_\_\_

This record of inspection is to be kept for not less than 12 months from the date indicated above.